

Ripley, Maine

DIAMETER	GAGE	YEAR INSTALLED	INSPECTION DATE
48"	12 (0.109 IN)	ESTIMATED 1984	JUNE, 2012
PROFILE	COATING	SOIL DATA	WATER DATA
2 2/3 X 1/2	ALUMINIZED TYPE 2	PH: N/A	PH: 6
		RESISTIVITY: N/A	RESISTIVITY: N/A
			FHWA ABRASION LEVEL: 2
			CHLORIDES: N/A
			CaCO ₃ : 100

IMAGES:



SOIL SIDE ALUMINUM COATING DATA:



- Surface area coated: 100%
- Minimum thickness: 0.00
- Maximum thickness: 1.13 (29 μm)
- Maximum pit depth: 2.31 mils

WATER SIDE ALUMINUM COATING DATA:



- Surface area coated: 0%
- Minimum thickness: 0.00
- Maximum thickness: 0.00
- Maximum pit depth: 41.00 mils

Ripley, Maine

ULTRA-SONIC PIPE THICKNESS (IN):

- TOP AVG = 0.095
- INVERT AVG = 0.090

* Avg of a minimum of 4 readings after cleaning using TI-25M Ultrasonic Wall Thickness Gauge

COMMENTS:

- Pipe and coating were in good condition